

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
CEDAR KEY WTP DISINFECTION BYPRODUCTS MONITORING PUBLIC NOTICE**

What happened?

Our water system did not meet the requirements of a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received from samples taken August 6, 2019, when averaged with quarterly results from the past year, show that our system exceeds the standards, or maximum contaminant levels (MCL), for Disinfection Byproducts (DBPs), which includes Total Trihalomethanes (TTHMs). The standard for TTHMs is 80 micrograms per liter ($\mu\text{g/L}$). Compliance is based on the locational running annual average (LRAA), which is the average of all quarterly results from the past year.

Contaminant & Date	Hodgson & Jernigan Ave.	Gulf Boulevard & Hodges Ave.
TTHMs LRAA following August 6, 2019 results	91.88	91.23

What should I do?

Some people who drink water containing TTHMs in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Any customers who are concerned about their exposure to DBPs may choose alternative sources of water for ingestion.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately.

What is being done?

We are testing a change in the primary disinfectant from chlorine to chlorine dioxide as a permanent fix for this problem. We will continue to monitor and report to you by public notice on future testing results.

For more information, please contact John McPherson, General Manager, at 352-543-5285 or 352-317-7431.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by CEDAR KEY WTP

State Public Water System ID#: 2380178

Date distributed: November 7, 2019